



## Certificate of Compliance

### Certification Details:

**Certificate No:** FC2Ls93111-8

**Status:** Certified

**Period:** 07/2004 - 03/2013

**Restrictions:** NONE

### Wilsonart Custom Laminate

### Wilsonart International

This product has been certified according to the GREENGUARD Indoor Air Quality (IAQ) Certification Program for Low Emitting Products

**Reference Standard:** GGPS.001 GREENGUARD IAQ Standard for Building Materials, Finishes, and Furnishings

**Product Type:** Furniture Components/Materials, Seating, and Free Standing Furniture and Furnishing Units

| Criteria                     | Allowable Limits           |
|------------------------------|----------------------------|
| TVOC <sup>1</sup>            | ≤ 0.25 µg/m <sup>3</sup>   |
| Formaldehyde                 | ≤ 0.025 ppm                |
| Total Aldehydes <sup>2</sup> | ≤ 0.05 ppm                 |
| Individual VOCs <sup>3</sup> | ≤ 0.1 TLV                  |
| 4-phenylcyclohexene          | ≤ 0.0033 µg/m <sup>3</sup> |

Listing of measured carcinogens and reproductive toxins as identified by California Proposition 65, the U.S. National Toxicology Program (NTP), and the International Agency on Research on Cancer (IARC) must be provided.

Any pollutant regulated as a primary or secondary outdoor air pollutant must meet a concentration that will not generate an air concentration greater than that promulgated by the National Ambient Air Quality Standard (U.S. EPA, code of Federal Regulations, Title 40, Part 50).

See referenced standard for a complete technical explanation.

<sup>1</sup> Defined to be the total response of measured VOCs falling within the C<sub>6</sub>-C<sub>16</sub> range, with responses calibrated to a toluene surrogate.

<sup>2</sup> Defined to be the total response of a target list of aldehydes (2-butanal; acetaldehyde; benzaldehyde; 2, 5-dimethylbenzaldehyde, 2-methylbenzaldehyde; 3-and/or 4-methylbenzaldehyde; butanal; 3-methylbutanal; formaldehyde; hexanal; pentanal; propanal), with each individually calibrated to a compound specific standard.

<sup>3</sup> Any pollutant not listed must produce an air concentration level no greater than 1/10 the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, Cincinnati, Ohio 45211-4438). Seating complies with ANSI/BIFMA X7.1-2011, ANSI/BIFMA M7.1-2011, and ANSI/BIFMA e3-2010 Credit 7.6.1

GREENGUARD Certification affirms that products meet the criteria of the referenced standard and the requirements of the specific certification program. Certification testing is conducted according to a consistent, defined protocol. The testing does not evaluate emissions under usage conditions other than those defined in the protocol and does not address potential environmental impact other than chemical and particle emissions.

The GREENGUARD Environmental Institute (GEI) is an industry independent, third-party certification organization that qualifies products for low chemical emissions. GREENGUARD Certification programs use defined product standards, test methodologies, product sample collection and handling procedures, program application processes and on-going verification procedures. GREENGUARD standards, methods, and procedures are available at [www.GREENGUARD.org](http://www.GREENGUARD.org).